## Vacuum Performance and Run-7

H.C. Hseuh July 10, 2006

# <u>Outline</u>

Major Vacuum Works during 2005 Shut Down and Run-6 Observations Upgrades during This Shutdown

Perspectives for Run-7

# Major Vacuum Work in 2005 Shutdown

RF region: re-arranged the storage cavities

Polarimeters: lowered outgassing and added pumps

IR10: remove PHOBOS Be pipes, replaced with NEG coated pipes

Cold Bore improvement: pre-pumping, added ion pumps and IPC

Warm Bore NEG coated pipes: ~ 178m (total to 430m)

AGS IPC upgrade: installed 40 IPCs for 80 IPs in H10 house (1/3)

### RF Related Work in Sector #4

### Relocation of SC: completed in 05 shutdown

Two SC, IPs, GVs, beam pipes, vacuum I&C Platform, crane, plumbing, cabling, ....

AC Tuner Repair/upgrade


SC Dampers Air Cooling Upgrade

CC PA Window Upgrade/testing: on going this summer


Yellow

QU4


RHIC Retreat 06, H.C. Hseuh July 10, 2006



Top view



#### Platforms w/ lifting cranes



## Polarimeter Vacuum Upgrade

During Run-5: long pump down time after target changes i.e.  $10^{-8}$  Torr after a week.


Achieved: reduce outgassing, faster pump down, higher UHV speeds


Identified high outgassing components: Peek insulators ( $\times$  5)


Added 500 I/s NEG cartridge pump and TSP sublimation (  $\times$  3)

Pump down time decreases by > 10 (i.e. low  $10^{-9}$  Torr in 24 hrs)

NEG Cartridge







Removed 3x4m Be beam pipes (high  $\Delta P$  in Run-4 Au x Au due to high  $\eta_e$ )

Installed two CERN electron detectors (ED) and two warm dipoles (WD)

Installed 8.5m NEG coated beam pipes

⇒ P@ low 10<sup>-11</sup> Torr

### Two warm dipoles (from yo5)

To enhance the electron signals


Gap: 24" L x 6" W x 5" H

B: < 500 Gauss






RFD/Energy analyzer < 300 eV



Stripe detectors 48×1mm



#### Cold Bore in Run-4 & Run-5


40 C-B sections, 28 x 20m, 12 x 500m C-B are usually at low e-10 Torr Observed C-B ΔP to e-7 Torr with high intensity Au, Cu and p^ ramps Cu: 5919, 6103-06, 6250, 6530, ... with 5e+9 x 40-49 bunches


P<sup>\*</sup>: 3812, 5258, 5350, 7329-37, 7935... with > 1 5e+13 @ 110-bunch modes

Most  $\Delta P$  were at triplets and Q4 ends a few  $\Delta P$  in the middle of arcs

During Run-6 (after C-B upgrade)

No significant  $\Delta P$  at triplets and in the middle of arcs Some  $\Delta P$  at Q4 ends ~ one decade lower (to e-8 Torr) with higher intensity (#7935 vs. #5350)





RHIC Retreat 06, H. July 10, 2000

## Cold Bore Upgrade (conti.)

#### Pre-2005

C-B were pumped down in 1999 to  $\sim 10^{-4}$  Torr No active pumping during annual warm up

P to ~  $10^{-1}$  Torr =  $\geq 10$  monolayers of adsorbed gas after cool down No He background found after warm up

### 2005 Shutdown

Sampled 5 arcs and 5 triplets with RGA  $H_2$  (90 - 14%)


Sections with highest  $\Delta P$ 

have highest H<sub>2</sub> (BI12-1, YO12-1)

### Gaol of Upgrade:

P < 10<sup>-6</sup> Torr before cooldown to reduce the physi-sorbed H2 to sub-sub-monolayers after cool down

ION INDUCED DESORPTION YIELD FOR CONDENSED HYDROGEN BOMBARDED BY H2\* IONS OR ELECTRONS



RHIC Retreat 06. H.C. Hseuh July 10, 2006


## 2005 Cold Bore Upgrade

### Installed:

Six fixed TMPs to pump the 12 arcs
Portable TMPs to pump the 28 triplets and inj.
Four ion pumps per long arc (every 120m)
One ion pump per triplet and inj. section
Pumped down all C-B during 05 shutdown

Arcs: ~2 months (~ $10^{-5}$ Torr)  $\Rightarrow$  IPs to  $10^{-7}$  Torr Triplets: ~2 weeks (~ $10^{-6}$ Torr)  $\Rightarrow$  IP to  $10^{-8}$  Torr

2006 Warm Up to 80K: All C-B at 10-9 Torr





C-B TMP for both arcs



Arc C-B IP mounted on cryostat

# NEG Coated Beam tubes in RHIC

```
NEG (Non-Evaporable Getter) Coating of Ti-Zr-V alloy
    sputter-coated on beam tubes, \sim 1 \, \mu m thick, by SAES Getters of Italy
    < 600m beam tubes of 1.2 km W-B can be installed w/ NEG
    activated at 250 C \times 2-4 hrs at end of in-situ bake cycles
    limited capacity & lifetime (< 10 activations) - not for high Q regions
57 m installed in 2003 shutdown - for evaluation
195 m installed in 2004 shutdown
178 m installed in 2005 shutdown
45 m to be installed this shutdown @ bi1, yo1, yo5
57m may be installed in 2007+ @ bo6, yi7, yo9 and bo10
IR10 and IR12 have NEG coated beam pipes of ~ 8m each
IR6 (Star) has ~ 5.6 m of NEG coated pipes
IR8 (Phenix), IR4 (RF), IR2 (Brahms) have none
```

# Major Vacuum Upgrades in 2006 Shutdown

IR12: beam shutter upgrade ( $\tau = 10,000$  cycles)

RF: window coating and evaluation (Ti, Cu, porcelain)

NEG coated pipes: ~ 45m @ bi1, yo1 and yo5 (total to 463m)

NEG coating of BBLR chambers: to be installed at bi5 and yo5

AGS ion pump controller upgrade:

Complete E18 house this shutdown

H10 was completed last year, A10 and Booster: 2007+

AGS TMP Control and Gauging Development:

Install and commission prototype TMP controllers @ A10 house PLC based controls to replace the Datacon based system Evaluate commercial gauge controllers for future upgrade

**EBIS**: Install cross-over pipes at LtB

Booster: Install new stripping foil chamber at BtA

## Run-7 Perspectives

Based on  $\triangle P$  during #7935 1.9×10<sup>+11</sup> p^ x 110 x 2

### Warm Bore

```
Low e-7 Torr:
    IR4 (AC dipole and common cavities - not baked)
    IR8 (Phenix), IR10 (CERN ED)
    bo2-3.2 (IPM), yi7 (collimators), yo9-3.2 (dump)
High e-8 Torr:
    yo1-3.2 (IPM)
    bi4-3.1/3.2 (AC/SC), yo4-3.1/3.2/3.3 (AC/SC/SCK)
    bo10-3.2 (dump), IR12 (gas jet)
Low e-8 Torr:
    IR2, bi1, yi2, yo5, bo6
    bi8 (collimators), yo9-3.1, bo10-3.1 (dump kickers)
    bi12-3.3, yo12-3.3 (polarimeters)
```

## Run-7 Perspectives Based on $\triangle P$ during #7935 $1.9 \times 10^{+11}$ p^ $\times$ 110 $\times$ 2

### Cold Bore

A few  $\Delta P$  of low e-8 Torr range

$$\Delta P(Q4) > \Delta P(Q1)$$

One decade lower that #5350 (with lower intensity)

Higher @ yo12, bi12, bo2 and yo1

 $\Delta P$  at other C-B were < e-9 Torr

Need to reduce migration of warm H2 to cold bore

i.e. Q  $(H_2) \ll 1e-9$  Torr x 500 l/s x 7 months

= ~ 10 Torr·liters ≈ 1 ML in arcs

Do not expect  $C-B \triangle P$  to be an issue for Run-7

W-B  $\Delta P$  will dominate

# Summary

Installed > 80% NEG coated pipes at possible Q3-Q4 locations

NEG became saturated in weeks at regions with un-baked components

Need to evaluate individual beam components for

In-situ baking (at higher temperature?) to lower outgassing

Automated TSP sublimation (e.g. once a week) will help

Need to upgrade hardware and develop software

Additional pumping - NEG cartridge?

 $C-B \triangle P$  is not significant at present intensity

Additional ion pumps may be added in the arcs

H<sub>2</sub> migration from W-B (at Q4 ends) needs to be minimized Polarimeters, IPMs, RF, ...

Develop upgrade plans in 2007 for luminosity goals in Run-8/9

IR8, IR6, IR4, IR2 and #4 Q3-Q4